


PRESS RELEASE-

## **CULVER SCHOOL DISTRICT WATER FREE OF LEAD**

All school districts are testing their water to determine levels of lead and safety of their water. Culver School District has received the results of our August testing. Umpqua Research Company completed the tests from the samples we sent in to them from each building. We have clean water and had great results! All buildings were tested except for the high school which was in a complete remodel, which included brand new plumbing throughout the building. This building will be included in future tests.

We will continue to comply with the regulations for lead testing in our water as set forth by the Oregon Department of Education.

\*Test Report from Umpqua Research Company Attached.



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6080512

Culver School District PO Box 259 Culver, OR 97734 370111	Project: General Project #: Test 1 2016 Client Contact: Attn: Tony Anderson	Date Reported: 08/20/16 Date Received: 08/05/16 12:15 Sampled By: Tony Anderson
--	---	---

**Method: EPA 200.8**

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6080512-01	Sample Location: MS-111-DW-C-P									
Lead		1030	ND	mg/L	0.002	0.02	08/04/16 08:08	08/09/16	DJP	
<b>Copper</b>			0.057	mg/L	0.010	1.3	08/04/16 08:08	08/09/16	DJP	
6080512-02	Sample Location: MS-107-DW-C-P									
Lead		1030	ND	mg/L	0.002	0.02	08/04/16 08:06	08/09/16	DJP	
<b>Copper</b>			0.036	mg/L	0.010	1.3	08/04/16 08:06	08/09/16	DJP	
6080512-03	Sample Location: ES-E28-F-C-P									
Lead		1030	ND	mg/L	0.002	0.02	08/04/16 07:57	08/09/16	DJP	
<b>Copper</b>			0.042	mg/L	0.010	1.3	08/04/16 07:57	08/09/16	DJP	
6080512-04	Sample Location: ES-117-DW-C-P									
Lead		1030	ND	mg/L	0.002	0.02	08/04/16 07:55	08/09/16	DJP	
<b>Copper</b>			0.475	mg/L	0.010	1.3	08/04/16 07:55	08/09/16	DJP	
6080512-05	Sample Location: CF-142-DW-C-P									
Lead		1030	ND	mg/L	0.002	0.02	08/04/16 08:03	08/09/16	DJP	
<b>Copper</b>			0.057	mg/L	0.010	1.3	08/04/16 08:03	08/09/16	DJP	
6080512-06	Sample Location: CF-144-F-C-P									
<b>Lead</b>		1030	0.004	mg/L	0.002	0.02	08/04/16 08:01	08/09/16	DJP	
<b>Copper</b>			0.102	mg/L	0.010	1.3	08/04/16 08:01	08/09/16	DJP	
6080512-07	Sample Location: GM-101-DW-C-P									
Lead		1030	ND	mg/L	0.002	0.02	08/04/16 07:48	08/09/16	DJP	
<b>Copper</b>			0.038	mg/L	0.010	1.3	08/04/16 07:48	08/09/16	DJP	
6080512-08	Sample Location: SS-HALL-DW-C-P									
Lead		1030	ND	mg/L	0.002	0.02	08/04/16 07:50	08/09/16	DJP	
<b>Copper</b>			0.045	mg/L	0.010	1.3	08/04/16 07:50	08/09/16	DJP	
6080512-09	Sample Location: SS-KT-F-C-P									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6080512

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	08/04/16 07:52	08/09/16	DJP	
Copper			0.031	mg/L	0.010	1.3	08/04/16 07:52	08/09/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6080512

### Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

---

Tom Williams, Laboratory Manager