



CULVER SCHOOL DISTRICT No. 4

STEFANIE GARBER, SUPERINTENDENT

DAVID SLAGHT, BOARD CHAIRMAN

Culver School District Lead in Drinking Water Testing Plan

- 1. Culver School District will test, every three years, selected water taps used for drinking or food preparation in all school buildings to identify any lead problems. The District will follow the Environmental Protection Agency's 3 T's Revised Technical Guidance to ensure that samples for lead are collected properly and from the correct places. An OHA-accredited drinking water laboratory will be used to analyze each sample for lead.**
- 2. Culver School District will prevent access to water taps that have more than 20 parts per billion (ppb) of lead. This will include shutting off taps, covering water fountains, and providing bottled water to students and staff members.**
- 3. All results from tests for lead in water will be available to students, families, and community within 5 days of the test results. The results will be published at www.culver.k12.or.us/departments/operations on the school's website.**
- 4. Following the drinking water sample collection and analysis, the District will determine the most appropriate corrective action, where required. EPA 3T's Guidance will be followed. If necessary, the District will replace the sources of lead in the building plumbing.**